



**SECTION 10 51 13
METAL LOCKERS**

PART 1 – GENERAL

1.01 SECTION INCLUDES

- A. Heavy Duty Knocked Down Lockers.
- B. Locker benches.

1.02 REFERENCES

- A. ADAAG - Americans with Disabilities Act, Accessibility Guidelines.

1.03 SUBMITTALS

- A. Submit under provisions of Section 01 33 00.
- B. Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Show the following:
 - 1. Dimensioned drawings including plans, elevations, and sections to show locker locations and interfaces with adjacent substrates.
 - 2. Details of assembly, erection, anchorage and clearance requirements.
- D. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and finishes.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Protect locker finish and adjacent surfaces from damage.

PART 2 – PRODUCTS

2.01 MANUFACTURERS

- A. Acceptable Manufacturer: Penco Products, Inc., which is located at: 2024 Cressman Rd. P. O. Box 158 ; Skippack, PA 19474-0158; Toll Free Tel: 800-562-1000; Tel: 610-666-0500; Fax: 610-666-7561; Email:general@pencoproducts.com; Web: www.pencoproducts.com
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01 25 00.
- D. Provide only metal lockers fabricated in the United States by a single domestic manufacturer.

10 51 13-1

Sold By

SchoolLockers.com

877.952.0151

2.02 MATERIALS

- A. Steel: Prime grade mild cold-rolled sheet steel free from surface imperfection, capable of taking a high-grade enamel finish and in compliance with ASTM A1008.
- B. Steel: Sheet steel components shall be fabricated using zinc-coated steel free from surface imperfection, capable of taking a high-grade enamel finish and in compliance with ASTM A879.
- C. Hooks: Zinc plated forged steel, ball ends.
- D. Bolts and Nuts: Zinc plated truss fin head bolts and hex nuts.

2.03 HEAVY DUTY LOCKERS

- A. Heavy Duty Lockers: All locker body components made of cold rolled steel specially formed for added strength and rigidity and to ensure tight joints at fastening points.
 - 1. Lockers with Doors: Penco Invincible II, knock-down lockers, with 6 inch legs (legs are standard).
 - 2. Lockers with Doors: Penco Invincible II, knock-down lockers, with no legs (no legs are optional).
- B. Locker Body Construction: Steel specially formed for added strength and rigidity and to ensure tight joints at fastening points.
 - 1. Sides, Bottoms, Tops, and Shelves:
 - a. 16 gauge steel.
 - b. Ventilation: 3/4 inch (19 mm) wide by 1-1/2 inch (38 mm) high diamond-shaped perforations.
 - c. Solid sides.
 - 2. Backs: Solid 18 gauge steel.
 - 3. Doors:
 - a. 14 gauge steel.
 - b. Ventilation: 3/4 inch (19 mm) wide by 1-1/2 inch (38 mm) high diamond-shaped perforations.
 - c. Solid doors.
 - 4. Tops and bottoms with three sides formed 90 degrees, the front offset formed to be flush with horizontal frame member.
 - 5. Shelves with four sides formed to 90 degrees, front edge having a second bend.
 - 6. Hole spacing in locker body construction: Not exceeding 9 inches (225 mm).
 - 7. Two- and three-tier lockers: Intermediate channel-shaped horizontal frame members attached to side frames with mortise and tenon construction, securely welded.
 - 8. Optional factory assembly of locker bodies using rivets.
- C. Locker Doors: One piece sheet steel.
 - 1. Multi-Point Latch Doors: Full channel formation of adequate depth to fully conceal lock bar on lock side, channel formation on hinge side, right angle formations across top and bottom, with holes for attaching number plates.
 - 2. Single Point Latch Doors: 14 gauge door reinforced by a full height 3-1/2 inch (89 mm) wide, 18 gauge vertical pan welded to the top, bottom and hinge side flanges and rear of door skin on 12 inch (305 mm), 15 inch (381 mm) and 18 inch (457 mm) wide doors. Provide a horizontal pan for doors wider than 18 inches (457 mm).
 - 3. Single Point Latch Doors: 14 gauge door reinforced by a full 18 gauge inner pan welded to outer door skin on all four sides.
 - a. Solid outer door, solid inner pan
 - b. Diamond perforated outer, offset diamond perforated inner pan.

10 51 13-2

Sold By

SchoolLockers.com

877.952.0151

- c. 3 inch or 6 inch louvered outer door, mini louvered inner pan.
- d. Mini louvered outer, mini louvered inner pan.
- 4. Doors over 15 inches (380 mm) Wide and 30 inches (0.762 m) high: Provided with 3 inch (75 mm) wide 20 gauge full height reinforcing pan welded to inside face of door at 6 inch (150 mm) centers.
- 5. Box Lockers (4 to 9 Tiers): Channel formations on lock and hinge sides; right angle flanges on top and bottom with friction catch door pull.
- 6. Provide holes for attaching number plates.
- 7. Ventilation:
 - a. Doors 20 inches (508 mm) or higher: 3/4 inch (19 mm) wide by 1-1/2 inch (38 mm) high diamond-shaped perforations.
 - b. All other doors: 7/16 inch (11 mm) wide by 15/16 inch (24 mm) high diamond-shaped perforations.
- 8. Ventilation: Provide louvered doors in manufacturer's standard louver pattern.
- 9. Ventilation: Provide louvered doors in manufacturer's standard mini-louver pattern, louvers 5/8 inch (15.8 mm) wide and 1/4 inch (6.3 mm) high.
- 10. Ventilation: Provide fully louvered doors in manufacturer's standard full louver pattern.
- 11. No Ventilation: Provide with solid doors.

D. Hinges:

- 1. Hinge: 0.074 inch (1.88 mm) thick sheet steel, double spun, full loop, tight pin, projection welded to door frame and securely fastened to the door.
 - a. Doors over 48 inches (1.066 m) high: Three 2 inch (51 mm) high five-knuckle hinges.
 - b. Doors 24 inches (609 mm) wide by 60 inches (1.524 m) or 72 inches (1.828 m) High: Four 2 inch (51 mm) high five-knuckle hinges.
 - c. All other doors: Two 2 inch (51 mm) high five-knuckle hinges.
- 2. Continuous Hinges: Continuous piano hinge for the full height of the door.

2.04 DOOR HANDLES AND LATCHING

A. 1, 2 and 3 Tier Lockers:

- 1. Single-point latching:
 - a. Recess handle in door.
 - b. Integral Pocket and Pull: 22 gauge brushed stainless steel securely fastened to door with two lugs and a positive tamper-resistant decorative fastener.
 - 1) Pocket Depth: Sufficient to prevent a combination padlock, built-in combination lock, or key lock from protruding beyond door face.
 - 2) Pull: Formed in pocket.
 - 3) Padlock Staple: Protruding through pocket.
 - c. Provide lock hole cover plate for use with padlocks.
 - d. Locking Device: 11 gauge steel hasp welded to locker frame; include surface for engaging the bolt of a built-in combination or key lock and anti-pry lug and slot to deter prying open when locked.
 - e. Firmly secure rubber silencers to locker frame.
- 2. Multi-point latching with recessed handles:
 - a. Recess finger-lift control handle in door.
 - b. Pocket: 22 gauge brushed stainless steel securely fastened to door with two tabs and a positive tamper-resistant decorative fastener; of depth sufficient to prevent a combination padlock, built-in combination lock, or key lock from protruding beyond door face.
 - c. Provide lock hole cover plate for use with padlocks.

- d. Attach 14 gauge formed steel lifting piece to latching channel with one concealed retaining lug and one rivet, assuring a positive two-point connection.
- e. Handle Finger Lift: Molded, sound-deadening, attached with rivet; padlock eye for use with 9/32 inch (7.1 mm) diameter padlock shackle.
- f. Latch Clip: Glass-filled nylon engaging the door frame and holding the door shut.
 - 1) Doors 60 inches (1.524 m) and 72 inches (1.828 m) high: Three points.
 - 2) Doors 20 inches (0.508 m) to 48 inches (1.22 m) high: Two points.
- g. Locking Device: Positive, automatic type, whereby locker may be locked when open, then closed without unlocking.
- h. Firmly secure one rubber silencer in frame at each latch hook.

B. 1, 2 and 3 Tier Lockers:

- 1. Single-point latching using double pan door:
 - a. Recess handle in door.
 - b. Integral Pocket and Pull: 22 gauge brushed stainless steel securely fastened to door with two lugs and a positive tamper-resistant decorative fastener.
 - 1) Pocket Depth: Sufficient to prevent a combination padlock, built-in combination lock, or key lock from protruding beyond door face.
 - 2) Pull: Formed in pocket.
 - 3) Padlock Staple: Protruding through pocket.
 - c. Provide lock hole cover plate for use with padlocks.
 - d. Locking Device: 11 gauge steel hasp welded to locker frame; include surface for engaging the bolt of a built-in combination or key lock and anti-pry lug and slot to deter prying open when locked.
 - e. Firmly secure rubber silencers to locker frame.
- 2. Cremone Latching Option: Handle shall be a heavy duty turn handle that engages the door frame on three sides. The top and bottom frames are engaged with 3/8 inch (9.5 mm) steel rods, and a 1/8 inch (3 mm) thick center latch engages at the side.
 - a. Double door configurations shall consist of a left hinged door secured its full length by the right hinged door when latched.
 - b. Handle Assembly shall be secured to door using a threaded lock nut to facilitate adjustment and removal for repair if necessary. Welded handle assemblies shall not be accepted.
- 3. Single-Point Latching for wrap around/rotary locks:
 - a. Recess Handle in door
 - b. Integral Pocket and Pull: 22 gauge brushed stainless steel securely fastened to door with two lugs and a positive tamper-resistant decorative fastener.
 - 1) Pocket Depth: Sufficient to prevent a combination padlock, built-in combination lock, or key lock from protruding beyond door face.
 - 2) Pull: Formed in pocket.
 - 3) Pocket punched for built-in lock mounting only. Make no provision for padlock use.
 - c. Locking Device: 11 gauge steel hasp welded to locker frame; include surface for secure wrap around vertical engagement by a built-in rotary-type lock to deter prying open when locked. Hasp must be adaptable to common horizontal throw locker lock and padlock use.
 - d. Firmly secure rubber silencers to locker frame.

C. Box Lockers (4 to 9 Tier):

10 51 13-4

Sold By

SchoolLockers.com

877.952.0151

1. Punch doors for use with padlocks or built-in locks.
 2. Equip doors for use with padlocks with an 18 gauge combination door pull, staple, and lock hole cover plate with integral friction catch.
- D. Box Lockers (4 to 9 Tier):
1. Finger-operated 11 gauge steel slam latch in each door with an electrogalvanized trigger and spring contained in a 14 gauge steel case welded to the door.
 2. Weld 13 gauge steel hasp to frame to engage spring latch.
 3. Securely install rubber bumpers in frame.

2.05 INTERIOR EQUIPMENT

- A. ADA-Compliant Lockers (Recessed Handles with Multi-Point Latch):
1. Single Tier Lockers: Hat shelf at maximum 48 inches (1.219 m) off the floor for unobstructed forward and side reach.
 2. Locker Compartment Bottom: Minimum of 15 inches (230 mm) off the floor, or an extra shelf placed 15 inches (381 mm) off the floor for unobstructed forward and side reach.
 3. Handicapped symbol attached to door.
 4. Hooks and rods as specified for other lockers.
- B. Athletic Lockers with Doors (Invincible II):
1. Single-Tier, 48 inches (1.219 m) or Higher: Shelf located approximately 9 inches (228 mm) below top of locker.
 2. Openings up to 18 inches (457 mm) deep: Three single-prong wall hooks and one double-prong ceiling hook.
 3. Openings 18 inches (475 mm) or over deep: Three single-prong wall hooks and one coat rod.
 4. Openings 30 inch (760 mm) and 36 inch (914 mm) high: Three single-prong wall hooks and one double prong ceiling hook.
 5. Openings 20 inch (508 mm) and 24 inch (610 mm) high: Three single prong wall hooks.

2.06 ACCESSORIES

- A. Number Plates: Provide each locker with a polished aluminum number plate, 2-1/4 inches (57 mm) wide by 1 inch (25 mm) high, with black numerals not less than 3/8 inch (9.5 mm) high; attach to face of door with two aluminum rivets.
- B. Closed Bases: 18 gauge closed metal front and end bases, finished to match lockers.
- C. Locks: Built-in flat key locks; control-key to same series.
- D. Locks: Built-in grooved key locks (pin tumbler); control-key to same series.
- E. Locks: Built-in three-number dialing combination locks capable of at least five different combinations changes; provide control key, combination change key, and combination control charts.
1. Horizontal bolt
 2. Wrap around/rotary bolt
- F. Padlocks: Control-keyed, three-number dialing combination type padlocks; provide control key. Mechanism must be resistant to "shimming".
- G. Coin-Operated Locks:
1. Coin return/deposit type.

10 51 13-5

Sold By

SchoolLockers.com

877.952.0151

- a. Token.
 - b. One quarter.
 - c. Two quarters.
- 2. Coin collect/pay type with cash box.
 - a. Token.
 - b. One quarter.
 - c. Two quarters.

- H. Continuous Sloped Hoods: 18 gauge steel, slope rise equal to 1/3 of the locker depth (18.5 degrees), plus a 1 inch (25 mm) vertical rise at front.
 - 1. Supplied in 72 inch (1829 mm) lengths only.
 - 2. Slip joints without visible fasteners at splice locations.
 - 3. Provide necessary end closures.
 - 4. Finish to match lockers.

- I. Continuous Sloped Hoods: 16 gauge steel, slope rise equal to 1/3 of the locker depth (18.5 degrees), plus a 1 inch (25 mm) vertical rise at front.
 - 1. Supplied in 72 inch (1829 mm) lengths only.
 - 2. Slip joints without visible fasteners at splice locations.
 - 3. Provide necessary end closures.
 - 4. Finish to match lockers.

- J. Finished End Panels: Minimum 16 gauge steel formed to match locker depth and height, 1 inch (25 mm) edge dimension; finish to match lockers; install with concealed fasteners.

- K. Front Fillers: 20 gauge steel formed in an angle shape, with 20 gauge slip joint angles formed in an angle shape with double bend on one leg forming a pocket to provide adjustable mating with angle filler.
 - 1. Attachment by means of concealed fasteners.
 - 2. Finish to match lockers.

- L. Zee Bases for Knock-Down Lockers without legs: 14 gauge, steel flanged outward at top for support of lockers, flanged inward at bottom for anchoring to floor.
 - 1. Height: 4 inches (101 mm).
 - 2. Height: 6 inches (150 mm).

- M. Recess Trim: 18 gauge steel, 3 inch (75 mm) face dimension.
 - 1. Vertical and/or horizontal as required.
 - 2. Standard lengths as long as practical.
 - 3. Attach to lockers with concealed clips.
 - 4. Provide necessary finish caps and splices.
 - 5. Finish to match lockers.

- N. Benches: Laminated selected hardwood, 1-1/4 inch (31 mm) full finished thickness, corners rounded and sanded, surfaces finished with two coats of clear lacquer.
 - 1. Width: 9-1/2 inches (240 mm) wide.
 - 2. Width: 12 inches (305 mm) wide.
 - 3. Width: 24 inches (610 mm) wide.
 - 4. Lengths: As shown.

- O. Heavy-Duty Bench Pedestals: Steel tubing with 10 gauge steel flanges welded to each end, 16-1/4 inches (412 mm) high, finish to match lockers.

- P. Stainless Steel Free-Standing Bench Pedestals: 2-inch (50 mm) diameter brushed 16 gauge stainless steel formed into a trapezoid, 14 inch (355 mm) wide bottom with two 5/16 inch (7.9 mm) diameter holes, top flange with four 5/16 inch (7.9 mm) diameter holes for fastening to bench

10 51 13-6

Sold By

SchoolLockers.com

877.952.0151

2.07 FABRICATION

- A. Fabricate lockers square, rigid, without warp, with metal faces flat and free of distortion.
- B. Knock-Down Lockers: Fabricate lockers on the unit principle, each locker with individual door and frame, individual top, bottom, back, and shelves, with common intermediate divisions separating compartments. Verify dimensions and arrangement before fabrication.
- C. Finish: Enamel powder coat paint finish electrostatically applied and properly cured to manufacturer's specifications for optimum performance. Finishes containing volatile organic compounds and subject to out-gassing are not acceptable. Locker exterior and interior shall be painted the same color.
 - 1. Powder Coat - Dry Thickness: 1 to 1.2 mils (0.025 to 0.03 mm).
 - 2. Powder Coat Plus - Dry Thickness: 2 to 2.2 mils (0.05 to 0.055 mm).
 - 3. Color: As selected from manufacturer's standard colors.
 - 4. Special Finish
 - a. Custom color
 - b. Anti-Graffiti
 - c. Anti-Microbial
 - d. TGIC
 - e. Ultra-Weatherable.

PART 3 – EXECUTION

3.01 EXAMINATION

- A. Do not begin installation until substrates and bases have been properly prepared.
- B. If substrate and bases are the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.02 INSTALLATION

- A. Install metal lockers and accessories at locations shown in accordance with manufacturer's instructions.
- B. Install lockers plumb, level, and square.
- C. Anchor lockers to floor and wall at 48 inches (1.219 m) or less, as recommended by the manufacturer.
- D. Bolt adjoining locker units together to provide rigid installation.
- E. Install sloping tops and metal fillers using concealed fasteners. Provide flush hairline joints against adjacent surfaces.
- F. Install front bases between legs without overlap or exposed fasteners. Provide end bases on exposed ends.
- G. Install benches by fastening bench tops to pedestals and securely anchoring to the floor using appropriate anchors for the floor material.

3.03 ADJUSTING AND CLEANING

10 51 13-7

Sold By

SchoolLockers.com

877.952.0151

- A. Adjust doors and latches to operate without binding. Verify that latches are operating satisfactorily.
- B. Adjust built-in locks to prevent binding of dial or key and ensure smooth operation prior to substantial completion.
- C. Touch-up with factory-supplied paint and repair or replace damaged products before substantial completion.

3.04 PROTECTION

- A. Protect installed products until completion of project.

END OF SECTION

Penco Products, Inc. reserves the right to vary specifications consistent with a policy of continuous product improvement.